

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:15 pm

PWS ID: UTAH16003 **Name:** MARYSVALE TOWN WATER SYSTEM

Legal Contact: MARYSVALEXX **Rating:** Approved
RONALD R BURR **Rating Date:** 11/18/1986

Address: 182 S 400 W **Activity Status:** Active
MARYSVALE, UT 84750

Phone Number: 435-326-4324

City Served (Area):

County: PIUTE COUNTY

System Type: Community **Last Inv Update:** 05/26/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 12/28/2010 **Total Dsgn Cap:**
Population: 380 **Surveyor:** JOHN VERCOE **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers Office Emergency	Email Address
AC	BURR, RONALD R		435-326-4324	ronaldburr@hotmail.com

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	210
			210 Total Svc Connections

Storage

Total Storage: 800,000 GAL **Number of Units:** 4 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	UPPER TANK	Ground	250,000 GAL	Concrete		A	NO
ST002	LOWER (OLD) TANK	Ground	150,000 GAL	Concrete		A	NO
ST003	LOWER (NEW) TANK	Ground	250,000 GAL	Concrete		A	NO
ST004	150,000 CONCRETE STORAGE TAN	Ground	150,000 GAL	Concrete		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	BIG SPRING CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	BIG SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	LOW. BUL. CYN SPRING	Inactive	SP				Yes	GW	Other		
WS003	PARK WELL	Active	WL	10	410 GPM	210 GPM	Yes	GW	Seasonal		

*Reports measured flow for wells, approved design capacity for all other sources.

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS004	BULLION CANYON 2009 WE	P	WL				Yes	GW	Permanent		

**Reports measured flow for wells, approved design capacity for all other sources.*